



**NOTES**

1. METER CHAMBER TO BE INSTALLED IN AN EASILY ACCESSIBLE LOCATION, GENERALLY IN THE CENTRE OF THE LOT BY PLUMBER AND CONFORM TO THE B.C. PLUMBING CODE
  2. METER BOX TO BE "JUMBO PLASTIC METER BOX" #190101 WITH JUMBO BOX LID #192103 GREEN w/SNAP LOCK C/W AYR-FOIL A2A FOIL BLANKET ON TOP OF SETTER OR APPROVED EQUAL.
  3. METER SETTER FOR 5/8" OR 3/4" METER TO BE MUELLER H-14104192238 WITH 375mm EXTENDED OUTLET OR APPROVED EQUIVALENT
  4. METER SETTER FOR 1" METER TO BE MUELLER H-14104042391 WITH 375mm EXTENDED OUTLET, OR APPROVED EQUIVALENT
  5. IN TRAFFIC AREAS METER BOX TO BE CONCRETE WITH A MINIMUM CLEAR OPENING OF 300mm X 508mm c/w FLUSH GALVANIZED CHECKER PLATE COVER WITH PICK HOLES AND 45mmØ OPENING FOR REMOTE METER SENSORS (H2O LOADING).
- APPROVED PRODUCTS:  
 #37 METER BOX  
 T266 SERVICE BOX
6. THE INTERNAL SPRING OF THE SINGLE CHECK VALVE IS TO BE REMOVED FOR ANY DWELLINGS CONSTRUCTED PRIOR TO 2006.

TITLE:

**OUTSIDE WATER METER CHAMBER FOR 19mm AND 25mm SERVICE CONNECTIONS  
(RENEWED SERVICES FOR CONSTRUCTION PROJECTS)**



**The Corporation of Delta**  
ENGINEERING DEPARTMENT

DATE: 2014-03-14

APPROVED: HF

DWG. No.

DESIGN:

DRAWN: YTC

L4.19B